

Substance	Sample Date	Results	MCL	DL	Source of Contaminate	Special Notes
Alpha	Average	0.175 pCi	15 pCi/l			
Antimony	18-Jul-16	<0.0004 mg/L	0.006 mg/L			
Arsenic	18-Jul-16	<0.0005 mg/L	0.01mg/L			
Barium	18-Jul-16	0.0271 mg/L	2 mg/L		Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits.	
Beryllium	18-Jul-16	<0.0003 mg/L	0.004 mg/L			
Cadmium	18-Jul-16	<0.0003 mg/L	0.005 mg/L			
Calcium	12-Apr-09	53 mg/L	NA		Naturally occurring or indicative of road salt.	
Chloride	9-Jul-12	<10.00 mg/L	250 mg/L		Naturally occurring or indicative of road salt contamination.	
Chlorine	Daily	1.3 ppm	4 mg/L	0.2 ppm	Added to water for the purpose of disinfection.	
Chromium	18-Jul-16	<0.0005 mg/L	0.1 mg/L			
Copper	4-Aug-15	90% was 0.98 mg/l	1.3mg/L		Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.	This sample represents the 90th percentile of the number of samples taken.
Cyanide (total)	18-Jul-16	<0.0100 mg/L	0.2 mg/L			
Dibromomethane	12-Apr-06	<0.5 ug/L	5 ug/L		Runoff/leaching from soil fumigation used on soybean, cotton, pineapples, and orchards.	
Fluoride	14-Apr-16	0.72 ppm	2.2ppm		Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.	
Gross Beta	1-Dec-00	1.3E 0+/-0.6E PCI/L	15PCI/L		Decay of natural deposits and man-made emissions.	
Haloacetic (HAA)	Quarterly	Running Avg.= 0.0265 mg/L	0.060 mg/L		By-product of drinking water chlorination needed to kill harmful organisms. THMs are formed when source water contains large amounts of organic matter.	
Iron	16-Jul-12	<0.051 mg/L	0.3 mg/L		An abundant element found naturally in the earth.	
Lead	4-Aug-15	90% was 0.0042 ppb	0.015ppb		Corrosion of household plumbing; Erosion of natural deposits.	This sample represents the 90th percentile of samples taken.
Manganese	16-Jul-12	<0.002 mg/L	0.05 mg/L			
Mercury	18-Jul-16	<0.0002 mg/L	0.002 mg/L			
Nickel	25-Jul-16	0.0020 mg/L	0.1 mg/L			
Nitrate as N	14-Apr-16	0.529 mg/L	10mg/L		Runoff from fertilizer use; leaching from septic tanks and sewers; erosion of natural deposits.	

Substance	Sample Date	Results	MCL	DL	Source of Contaminate	Special Notes
Radium 226	Average	0.08 pCi	5 pCi/L		Naturally-occurring radioactive gas found in soil and outdoor air.	
Radium 228	Average	0.22 pCi	5 pCi/L		Naturally-occurring radioactive gas found in soil and outdoor air.	
Selenium	18-Jul-16	<0.0030 mg/L	0.05 mg/L			
Silver	13-Jul-12	<0.0010 mg/L	0.1 mg/L			
Sodium	6-Jun-13	12.4 mg/L	NA		Natural occurring; road salt; water softeners; animal waste.	
Sulfate as so4	10-Jul-12	<10.00 mg/L	250mg/L		Naturally occurring.	
Thallium	18-Jul-16	<0.0003 mg/L	0.002 mg/L			
Thihalomethanes (THM)	Quarterly	Running Avg.= 0.0318 mg/L	0.080 mg/L		By-product of drinking water chlorination needed to kill harmful organisms. THMs are formed when source water contains large amounts of organic matter.	
Zinc	6-Jun-13	1.25 mg/L	5 mg/L		Corrosion of household plumbing.	